


I. LOCATION OF WELL

County Name Henn

Township Name Bloomington Township Number 115 N Range Number 21 Section No. 6

Distance and Direction from Road Intersections or Street Address and City of Well Location 8515-W 108th St Bloomington, Minn

Show exact location of well in section grid with "X"



Addition Name Block Number Lot Number

Sketch map of well location. X 1-C 48

2. FORMATION LOG

Table with columns: COLOR, HARDNESS OF FORMATION, FROM, TO. Rows include: Black Dirt (RUVU SOIL S 0 6), Red sand (Q FUR S 6 24), Gray sand (Q FUG S 24 70), Blue Clay (QTUG M 70 98), Blue Clay & sand (QUUG M 98 247), Brown Pea gravel (QFUB H 247 354), yellow shale (CSLF M 354 405), Green shales sandrock (CSLF M 405 441).

116-21-31 cc add Ag. CSTL-CFRN elev. 833' 104-C

LOCATED BY box with checkboxes: 1- Address Verification (checked), 2- Name on Mailbox, 3- Lot-Block, 4- Plat Book, 5- info. From Owner, 6- Info. From Neighbor, 7- Other, Can't Locate State Why.

15. REMARKS, ELEVATION, SOURCE OF DATA, etc.

RECEIVED JUN 10 1982 MINN. GEOLOGICAL SURVEY COPY

DEPARTMENT OF HEALTH WATER WELL RECORD

MINNESOTA UNIQUE WELL NO. I 190471 u

3. PROPERTY OWNER'S NAME Geo Rybolt, Jr Address 8515-W 108th St Bloomington Minn 55431

4. WELL DEPTH (completed) 441 ft. Date of Completion 4/24/82

- 5. Drilling methods: 1 Cable tool, 2 Helium rod, 3 Rotary, 4 Reverse, 5 Air, 6 Jetted, 7 Driven, 8 Bored, 9 Power Auger, 10 Dug.

- 6. USE: 1 Domestic, 2 Irrigation, 3 Test Well, 4 Public Supply, 5 Municipal, 6 Air Conditioning, 7 Industry, 8 Commercial, 9.

7. CASING: 1 Black threaded, 2 Galv., 3 Plastic. HEIGHT: Above/Below. HOLE DIAM: 4 in. to 387 ft. Weight 12 lbs./ft.

8. SCREEN: Make, Type, Slot/Gauze, Length, FITTINGS.

9. STATIC WATER LEVEL: 120 ft. below land surface. Date Measured 4/24/81

10. PUMPING LEVEL (below land surface): 120 ft. after 1 hrs. pumping 15 g.p.m.

11. WELL HEAD COMPLETION: 1 Pitless adapter, manufacturer Whitewater, model sub.

12. WELL GROUTED? Yes X No. Grout material Bentonite.

13. NEAREST SOURCES OF POSSIBLE CONTAMINATION: 50 feet SE direction. Well disinfected upon completion? Yes X No.

14. PUMP: Date installed 5/3/82, Manufacturer's Name Mc Donald, Model Number sub, HP 1, Volts 230, Length of drop pipe 147 ft. capacity 10 g.p.m., Material of drop pipe Water pipe.

16. WATER WELL CONTRACTOR'S CERTIFICATION

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. 19189 Benson's Wells Pump Co Licensee Business Name License No. 1955-Shannon Rd Address D.L. Benson 6/1/82 Signed Benson 4/24/82 Date Name of Driller



190471

5/74 30M 7/78 30M 7/78 30M 2/82 10M